

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0811:134 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Federal Signal Corp., 2645 Federal Signal Dr., University Pk, IL 60466-3195
Contact: *Leonard Steinbeigle (708) 534-3400

DESIGN: Model 224XSTHI strobe lights with clear lens. Refer to listee's data sheet for additional product description and operational considerations.

RATING: Candela: 15 cd
Electrical: 120/240 VAC, 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for use with separately listed compatible fire alarm control units. Suitable for the hearing impaired application (with clear lens only). Intended for use on wall or ceiling in non-sleeping areas. For indoor use only. Enclosure is rated NEMA or Type 4x and IP66.

*Rev. 06-18-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager